OCEAN KAMP RESIDENTIAL PROJECT

PRELIMINARY FIRE FLOW REQUIREMENTS

Residential Area	Maximum Building Area (1)	Fire Flow Requirement	Reduced Fire Flow Requirement (2)
North Residential, Areas C-E	22,303 sf	3,250 gpm	1,625 gpm
East Residential, Area A	12,573 sf	4,000 gpm	2,000 gpm
East Residential, Area B	14,599 sf	3,000 gpm	1,500 gpm
East Residential, Affordable Apartments	72,422 sf	7,250 gpm	3,625 gpm